



ADDENDUM 1 OF 1 – THURSDAY, JUNE 13, 2024

SOLICITATION NUMBER: 2024 STS-31
SOLICITATION TITLE: SIDEWALK REPAIRS
DUE DATE: TUESDAY, JUNE 18, 2024 AT 3:00 PM EST

THIS DOCUMENTATION MUST BE INCLUDED IN YOUR SUBMITTED SEALED BID FOR THE BID TO BE CONSIDERED.

1. Are the dimensions at each areas specific? For example: 202 Zetterower, significant cracking and damage to each driveway is evident but not listed. Please advise.

Also, existing sidewalk has shell topping embedded. Are we matching existing or going back with straight 3000psi concrete?

The dimensions at each area are not specific, each area of concern will be different and we are just going back with 3000 psi concrete in all areas.

2. If the driveway aprons are in need of repair at the sidewalk locations, then they need to be included in the bid for repairs also.

RECEIPT OF ADDENDUM 1 OF 1 ACKNOWLEDGED: SIGNATURE: _____