



ADDENDUM 3 OF 3 – TUESDAY, JUNE 18, 2024

**SOLICITATION NUMBER:** ITB 2024 ENG-128  
**SOLICITATION TITLE:** COS STREET RESURFACING FY 2024  
**DUE DATE:** ~~TUESDAY~~ WEDNESDAY, JUNE 26, 2024 AT 3:30 PM EST

**THIS DOCUMENTATION MUST BE INCLUDED IN YOUR SUBMITTED SEALED BID FOR THE BID TO BE CONSIDERED.**

1. Please confirm the limits of asphalt placement on Knight drive? I noticed GSU has offsite parking that ties into Knight drive, as well as a wide paved shoulder in the radius.

No parking areas nor extra shoulder width will be resurfaced on Knight Drive. Resurfacing only applies to the width of the roadway, which will vary between approximately 24 - 28 ft since the width changes. We will consider the radius for this road to be approximately 28 ft. Contractor can request for the Engineering Dept. to mark any limits prior to work.

2. Please verify intent for 6" GABC item? Presumably, this is for the isolated deep patching called out in the project specific requirements.

6" GAB is for isolated deep patching. Contractor can request for the Engineering Dept. to mark any limits prior to work.

3. Please verify the limits for all driveways and intersection tie ins?

Driveways and intersections will require tie downs of no more than 1 ft. unless there are extenuating circumstances. Contractor can request for the Engineering Dept. to mark any limits prior to work.

RECEIPT OF ADDENDUM 1 OF 1 ACKNOWLEDGED: SIGNATURE: \_\_\_\_\_